

QUICK REFERENCE DATA

*SA(1,2)BE4M Series Residential Split System Air Conditioner

14 SEER

MODEL NUMBER: *SA(1,2)BE4M	1SN18K	1SN24K	1SN30K	1SN36K	1SN42K	1SN48K	1SN60K
REFRIGERANT SUCTION LINE O.D.* NOTE: Liquid line is 3/8" O.D. for entire length.	3/4"	3/4"	3/4"	3/4"	7/8"	7/8"	7/8"
	3/4"	3/4"	3/4"	7/8" (1)	7/8"	7/8"	1-1/8" (2)
	3/4"	3/4"	3/4"	7/8" (1)	7/8"	7/8"	1-1/8" (2)
REFRIGERANT CHARGE: R-410A in ounces for outdoor unit, indoor unit and 15' line set. (3)	53	58	60	69	86	86	95

(1) Requires 7/8" to 3/4" reducer from line to unit.

(2) Requires 1-1/8" to 7/8" reducer from line to unit.

(3) Additional charge for line sets above 15 feet. Values based on suction line as follows with 3/8" liquid line.

(a) 3/4" = 0.6 oz. per additional foot.

(b) 7/8" = 0.7 oz. per additional foot.

(c) 1 1/8" = 0.8 oz. per additional foot.

*For other line set dimensions, refer to the Application Guidelines for Refrigerant Lines Addendum.

Table 1. Physical Data

MODEL NUMBER: *SA(1,2)BE4M	1SN18K	1SN24K	1SN30K	1SN36K	1SN42K	1SN48K	1SN60K
ID RESTRICTOR SUPPLIED WITH OD UNIT:	0.050	0.057, 0.058	0.062	0.068, 0.069	--	0.077	--
OUTDOOR UNIT BOM CHARGE (OZ.)	53	58	60	69	86	86	95
MODELS	SUPPLIED WITH ID	REQUIRED RESTRICTOR OR TXV (CHARGE ADDITION (OZ) / RATED AIRFLOW (SCFM))					
B6BMM0							
B6BMM024K-A	0.055	0.050 (3 / 660)	0.058 (2 / 730)	--	--	--	--
B6BMM024K-B	0.055	0.050 (4 / 660)	0.058 (2 / 715)	--	--	--	--
B6BMM030K-A	0.062	--	--	0.062 (-5 / 895) ‡	--	--	--
B6BMM030K-B	0.062	--	--	0.062 (-5 / 895) ‡	--	--	--
B6BMM042K-B	0.074	--	--	--	0.069 (3 / 1225)	0.074 (-4 / 1260) ‡	--
B6BMM060K-C	0.087	--	--	--	--	0.077 (0 / 1440)	0.087 (-3 / 1635) ‡
B6BMMX							
B6BMMX24K-A	669564	669564 (4 / 600)	669564 (0 / 715)	--	--	--	--
B6BMMX24K-B	669564	669564 (4 / 600)	669564 (0 / 715)	--	--	--	--
B6BMMX30K-A	669565	--	--	669565 (3 / 945)	--	--	--
B6BMMX30K-B	669565	--	--	669565 (3 / 1015)	--	--	--
B6BMMX36K-B	669566	--	--	--	669566 (7 / 1190)	--	--
B6BMMX48K-C	669568	--	--	--	--	669568 (6 / 1375)	669568 (14 / 1670)
B6BMMX60K-C	669578	--	--	--	--	--	669578 (0 / 1545)
B6BW							
B6BW-019K(*)	0.050	0.050 (2 / 635)	--	--	--	--	--
B6BW-030K(*)	0.060	--	0.057 (0 / 850)	0.060 (5 / 880)	--	--	--
B6BW-036K(*)	0.069	--	--	--	0.068 (5 / 1185)	--	--

NOTES:

‡ Requires REMOVAL of refrigerant from unit.

THE CHARGE ADDITIONS PROVIDED IN THIS DOCUMENT ARE ESTIMATES BASED ON TEST DATA AND SHOULD ONLY BE A STARTING POINT. AFTER FOLLOWING THESE DIRECTIONS PLEASE ADJUST THE REFRIGERANT AMOUNT BASED ON THE APPROPRIATE CHARGING TABLES OR CHARTS IN THE INSTALLATION INSTRUCTIONS OR CHARGING LABEL.

Table 2. Restrictor or TXV / Charge Addition (Oz)

Instructions:

1. Find the column for the model of outdoor unit that is being installed.
2. Find the row for the model of the indoor unit that is being installed.
3. Find the cell in the table in which this row and column meet. In this cell the appropriate orifice / TXV and charge addition for this match are listed. If the text in this cell is BOLD, then a change of orifice is necessary.
4. If a change in restrictor is necessary, then the appropriate restrictor will already be supplied with the outdoor unit.

Examples:

- For the *SA(1,2)BE4M1SN30K / C7B(A,H)M03036(C,U)-B the appropriate restrictor is 0.062 and no additional refrigerant will need to be added. (CHANGE IN RESTRICTOR)
- For the *SA(1,2)BE4M1SN48K / B6EMMX48K-C match, the appropriate TXV is the 669852 and 14 ounces of refrigerant will need to be added. (CHANGE IN CHARGE)

MODEL NUMBER: *SA(1,2)BE4M		1SN18K	1SN24K	1SN30K	1SN36K	1SN42K	1SN48K	1SN60K
ID RESTRICTOR SUPPLIED WITH OD UNIT:		0.050	0.057, 0.058	0.062	0.068, 0.069	--	0.077	--
OUTDOOR UNIT BOM CHARGE (OZ.)		53	58	60	69	86	86	95
MODELS	SUPPLIED WITH ID	REQUIRED RESTRICTOR OR TXV (CHARGE ADDITION (OZ) / RATED AIRFLOW (SCFM))						
B6EM								
B6EMMX24K-A	669564	669564 (4 / 540)	669564 (0 / 770)	--	--	--	--	--
B6EMMX24K-B	669564	669564 (4 / 540)	669564 (0 / 770)	--	--	--	--	--
B6EMMX30K-A	669565	--	--	669565 (3 / 1000)	--	--	--	--
B6EMMX30K-B	669565	--	--	669565 (3 / 1000)	--	--	--	--
B6EMMX36K-B	669566	--	--	--	669566 (9 / 1100)	--	--	--
B6EMMX42K-B	669567	--	--	--	--	669567 (0 / 1255)	--	--
B6EMMX48K-C	669852	--	--	--	--	669852 (0 / 1490)	669852 (14 / 1450)	--
B6EMMX60K-C	669578	--	--	--	--	--	--	669578 (0 / 1535)
B6EW								
B6EW-X18K	669564	669564 (-2 / 550) ‡	--	--	--	--	--	--
B6EW-X25K	669564	--	669564 (-14 / 820) ‡	--	--	--	--	--
B6EW-X30K	669565	--	--	669565 (1 / 975)	--	--	--	--
B6EW-X36K	669566	--	--	--	669566 (-7 / 1070) ‡	--	--	--
B6VMMX								
B6VMMX24K-A	669564	669564 (4 / 540)	669564 (0 / 770)	--	--	--	--	--
B6VMMX24K-B	669564	669564 (4 / 540)	669564 (0 / 770)	--	--	--	--	--
B6VMMX30K-A	669565	--	--	669565 (3 / 1000)	--	--	--	--
B6VMMX30K-B	669565	--	--	669565 (3 / 1000)	--	--	--	--
B6VMMX36K-B	669566	--	--	--	669566 (9 / 1100)	--	--	--
B6VMMX42K-B	669567	--	--	--	--	669567 (0 / 1255)	--	--
B6VMMX48K-C	669568	--	--	--	--	669568 (0 / 1490)	669568 (14 / 1450)	--
B6VMMX60K-C	669578	--	--	--	--	--	--	669578 (0 / 1500)

NOTES:

‡ Requires REMOVAL of refrigerant from unit.

THE CHARGE ADDITIONS PROVIDED IN THIS DOCUMENT ARE ESTIMATES BASED ON TEST DATA AND SHOULD ONLY BE A STARTING POINT. AFTER FOLLOWING THESE DIRECTIONS PLEASE ADJUST THE REFRIGERANT AMOUNT BASED ON THE APPROPRIATE CHARGING TABLES OR CHARTS IN THE INSTALLATION INSTRUCTIONS OR CHARGING LABEL.

Table 4. Restrictor or TXV / Charge Addition (Oz) - Continued

Instructions:

1. Find the column for the model of outdoor unit that is being installed.
2. Find the row for the model of the indoor unit that is being installed.
3. Find the cell in the table in which this row and column meet. In this cell the appropriate orifice / TXV and charge addition for this match are listed. If the text in this cell is **BOLD**, then a change of orifice is necessary.
4. If a change in restrictor is necessary, then the appropriate restrictor will already be supplied with the outdoor unit.

Examples:

- For the *SA(1,2)BE4M1SN30K / C7B(A,H)M03036(C,U)-B the appropriate restrictor is 0.062 and no additional refrigerant will need to be added. (CHANGE IN RESTRICTOR)
- For the *SA(1,2)BE4M1SN48K / B6EMMX48K-C match, the appropriate TXV is the 669852 and 14 ounces of refrigerant will need to be added. (CHANGE IN CHARGE)

MODEL NUMBER: *SA(1,2)BE4M		1SN18K	1SN24K	1SN30K	1SN36K	1SN42K	1SN48K	1SN60K
ID RESTRICTOR SUPPLIED WITH OD UNIT:		0.050	0.057, 0.058	0.062	0.068, 0.069	--	0.077	--
OUTDOOR UNIT BOM CHARGE (OZ.)		53	58	60	69	86	86	95
MODELS	SUPPLIED WITH ID	REQUIRED RESTRICTOR OR TXV (CHARGE ADDITION (OZ) / RATED AIRFLOW (SCFM))						
C6								
C6B(A,H)-X24(C,U)-A	669564	669564 (20 / 550)	669564 (18 / 770)	--	--	--	--	--
C6B(A,H)-X24(C,U)-B	669681	669681 (20 / 550)	669681 (18 / 770)	--	--	--	--	--
C6B(A,H)-X30(C,U)-A	669565	--	--	669565 (14 / 950)	--	--	--	--
C6B(A,H)-X30(C,U)-B	669682	--	--	669682 (14 / 950)	--	--	--	--
C6B(A,H)-X30(C,U)-C	669682	--	--	669682 (14 / 1000)	--	--	--	--
C6B(A,H)-X36(C,U)-B	669683	--	--	--	669683 (24 / 1150)	--	--	--
C6B(A,H)-X36(C,U)-C	669683	--	--	--	669683 (24 / 1150)	--	--	--
C6B(A,H)-X42(C,U)-B	669684	--	--	--	--	669684 (9 / 1210)	--	--
C6B(A,H)-X48(C,U)-C	669852	--	--	--	--	--	669852 (36 / 1435)	--
C6B(A,H)-X48(C,U)-D	669852	--	--	--	--	--	669852 (36 / 1435)	--
C6B(A,H)-X60(C,U)-C	669686	--	--	--	--	--	--	669686 (21 / 1660)
C6B(A,H)-X60(C,U)-D	669686	--	--	--	--	--	--	669686 (21 / 1660)
C7+TXV								
C7B(A,H)M01824(C,U)-A+TXV	0.048	920668A (4 / 675)	920669A (0 / 845)	--	--	--	--	--
C7B(A,H)M01824(C,U)-B+TXV	0.055	920668A (4 / 675)	920669A (0 / 845)	--	--	--	--	--
C7B(A,H)M030(C,U)-C+TXV	0.061	--	--	920670A (6 / 945)	--	--	--	--
C7B(A,H)M03036(C,U)-A+TXV	0.061	--	--	920670A (6 / 945)	--	--	--	--
C7B(A,H)M03036(C,U)-B+TXV	0.067	--	--	920670A (6 / 945)	--	--	--	--
C7B(A,H)M03642(C,U)-B+TXV	0.071	--	--	--	920670A (9 / 1110)	920671A (0 / 1300)	--	--
C7B(A,H)M03648(C,U)-C+TXV	0.067	--	--	--	920670A (8 / 1110)	920671A (0 / 1305)	--	--
C7B(A,H)M048(C,U)-C+TXV	0.077	--	--	--	--	--	920672A (16 / 1525)	--
C7B(A,H)M048(C,U)-D+TXV	0.077	--	--	--	--	--	920672A (16 / 1525)	--
C7B(A,H)M060(C,U)-C+TXV	0.083	--	--	--	--	--	--	920673A (0 / 1540)
C7B(A,H)M060(C,U)-D+TXV	0.083	--	--	--	--	--	--	920673A (0 / 1540)

NOTES:

‡ Requires **REMOVAL** of refrigerant from unit.

THE CHARGE ADDITIONS PROVIDED IN THIS DOCUMENT ARE ESTIMATES BASED ON TEST DATA AND SHOULD ONLY BE A STARTING POINT. AFTER FOLLOWING THESE DIRECTIONS PLEASE ADJUST THE REFRIGERANT AMOUNT BASED ON THE APPROPRIATE CHARGING TABLES OR CHARTS IN THE INSTALLATION INSTRUCTIONS OR CHARGING LABEL.

Table 4. Restrictor or TXV / Charge Addition (Oz) - Continued

Instructions:

1. Find the column for the model of outdoor unit that is being installed.
2. Find the row for the model of the indoor unit that is being installed.
3. Find the cell in the table in which this row and column meet. In this cell the appropriate orifice / TXV and charge addition for this match are listed. If the text in this cell is **BOLD**, then a change of orifice is necessary.
4. If a change in restrictor is necessary, then the appropriate restrictor will already be supplied with the outdoor unit.

Examples:

- For the *SA(1,2)BE4M1SN30K / C7B(A,H)M03036(C,U)-B the appropriate restrictor is 0.062 and no additional refrigerant will need to be added. (CHANGE IN RESTRICTOR)
- For the *SA(1,2)BE4M1SN48K / B6EMMX48K-C match, the appropriate TXV is the 669852 and 14 ounces of refrigerant will need to be added. (CHANGE IN CHARGE)

MODEL NUMBER: *SA(1,2)BE4M		1SN18K	1SN24K	1SN30K	1SN36K	1SN42K	1SN48K	1SN60K
ID RESTRICTOR SUPPLIED WITH OD UNIT:		0.050	0.057, 0.058	0.062	0.068, 0.069	--	0.077	--
OUTDOOR UNIT BOM CHARGE (OZ.)		53	58	60	69	86	86	95
MODELS	SUPPLIED WITH ID	REQUIRED RESTRICTOR OR TXV (CHARGE ADDITION (OZ) / RATED AIRFLOW (SCFM))						
C7-0								
C7B(A,H)M01824(C,U)-A	0.048	0.050 (0 / 675)	0.058 (0 / 815)	--	--	--	--	--
C7B(A,H)M01824(C,U)-B	0.055	0.050 (0 / 675)	0.058 (0 / 815)	--	--	--	--	--
C7B(A,H)M030(C,U)-C	0.061	--	--	0.062 (0 / 880)	--	--	--	--
C7B(A,H)M03036(C,U)-A	0.061	--	--	0.062 (0 / 880)	--	--	--	--
C7B(A,H)M03036(C,U)-B	0.067	--	--	0.062 (0 / 880)	--	--	--	--
C7B(A,H)M03642(C,U)-B	0.071	--	--	--	0.069 (0 / 1110)	--	--	--
C7B(A,H)M03648(C,U)-C	0.067	--	--	--	0.069 (0 / 1110)	--	0.077 (-8 / 1455) ‡	--
C7B(A,H)M048(C,U)-C	0.077	--	--	--	--	--	0.077 (0 / 1455)	--
C7B(A,H)M048(C,U)-D	0.077	--	--	--	--	--	0.077 (0 / 1455)	--
C7-X								
C7B(A,H)MX24(C,U)-A	669681	669681 (4 / 675)	669681 (0 / 845)	--	--	--	--	--
C7B(A,H)MX24(C,U)-B	669681	669681 (4 / 675)	669681 (0 / 845)	--	--	--	--	--
C7B(A,H)MX30(C,U)-A	669682	--	--	669682 (6 / 945)	--	--	--	--
C7B(A,H)MX30(C,U)-B	669682	--	--	669682 (6 / 945)	--	--	--	--
C7B(A,H)MX36(C,U)-B	669683	--	--	--	669683 (8 / 1110)	--	--	--
C7B(A,H)MX36(C,U)-C	669683	--	--	--	669683 (8 / 1110)	--	--	--
C7B(A,H)MX42(C,U)-C	669684	--	--	--	--	669684 (0 / 1305)	--	--
C7B(A,H)MX48(C,U)-C	669852	--	--	--	--	--	669852 (16 / 1525)	--
C7B(A,H)MX48(C,U)-D	669852	--	--	--	--	--	669852 (9 / 1525)	--
C7B(A,H)MX60(C,U)-C	669686	--	--	--	--	--	--	669686 (0 / 1540)
C7B(A,H)MX60(C,U)-D	669686	--	--	--	--	--	--	669686 (0 / 1540)

NOTES:

‡ Requires **REMOVAL** of refrigerant from unit.

THE CHARGE ADDITIONS PROVIDED IN THIS DOCUMENT ARE ESTIMATES BASED ON TEST DATA AND SHOULD ONLY BE A STARTING POINT. AFTER FOLLOWING THESE DIRECTIONS PLEASE ADJUST THE REFRIGERANT AMOUNT BASED ON THE APPROPRIATE CHARGING TABLES OR CHARTS IN THE INSTALLATION INSTRUCTIONS OR CHARGING LABEL.

Table 4. Restrictor or TXV / Charge Addition (Oz) - Continued

