Installation Instructions

ADDENDUM

ica Drive Variable Speed Ultra-High SEER Split System

This addendum is a supplement to unit Installation Instructions concerning controller thermostat connections. NORDYNE stresses the requirement that iQ system communication wires be run with **SHIELDED CABLE** as indicated in Installation Instructions included with the unit.

NORDYNE furthermore requires the shielded cable be **grounded only** at the indoor section of the system.

