WIRING DIAGRAM

LS

Grey

Yellow

Top - 10.0

240V

24V

Red -

- Black - 4 - Blue - 3

Model: E2EH-010HB

CB-A

Cont 1

Fuse

Red Pig-Tail

White Pig-Tail

╢



СВ-А ∓

6 Org.

С

Cont

IFM

Н

Transformer

Grey Pig-Tail

(See Note 7)

Switch circuit breakers to the "off" position before servicing the furnace.

Notes:

- See unit data label for recommended supply wire sizes.
- 2) Thermostat anticipator setting : 0.30 Amps
- To change blower speed on units without a relay box installed refer to installation instructions
- Refer to furnace and/or relay box installation instructions for thermostat connections.
- If any wire in this unit is to be replaced it must be replaced with 105°C thermoplastic copper wire of the same gauge.
- Not suitable for use on systems exceeding 120V to ground.
- This wire is used with some accessories. See accessory Installation Instructions for further detail.
- 8) Refer to Installation Instructions for complete wiring diagram.



CB = Circuit Breaker E = Heater Element IFS = Fan Switch IFM = Fan Motor Cont = Contactor LS = Limit Switch







(Replaces 7101710