WIRING DIAGRAM

Model: E3EH-010H



Switch circuit breakers to the "off" position before servicing the furnace.

Notes:

- 1) See unit data label for recommended supply wire sizes.
- 2) Thermostat anticipator setting : 0.20 Amps
- To change blower speed on units without a relay box installed refer to installation instructions
- Refer to furnace and/or relay box installation instructions for thermostat connections.
- If any wire in this unit is to be replaced it must be replaced with 105° C thermoplastic copper wire of the same gauge.
- 6) Not suitable for use on systems exceeding 120V to ground.
- 7) This wire is used with some accessories. See accessory Installation Instructions for further detail
- 8) Refer to Installation Instructions for complete wiring diagram.

Legend:

IFM = Fan Motor
CB = Circuit Breaker
E = Heater Element
IFS = Fan Switch
Cont = Contactor
LS = Limit Switch
= Fan Plug

710380A (Replaces 7103800)



