
WIRING DIAGRAM

H3HK005H-01B (Without Circuit Breaker) H4HK005H-11B (With Circuit Breaker) H4HK003H-01B (Without Circuit Breaker) H4HK005H-01B (Without Circuit Breaker) 3 kW,5kW, 1-Phase Electric Heater Kit



CIRCUIT

BREAKER

(Circuit breaker models only)

SUPPLY VOLTAGE

NOTES

- Circuit breakers (if supplied) are not wired to heater kit by the factory, see Installation Instructions for wiring procedure.
- If any of the original wire supplied with this unit must be replaced, it must be replaced with wiring material of the same gauge size and temperature rating.
- The installation of this heater kit may require a change in the blower speed tap connection. See Installation Instructions for details.
- 4) Use copper conductors with a minimum temperature rating of 60°C for supply connections.



GROUND

710394B (Replaces 710394A)

LEGEND:

FIELD WIRING ---LOW VOLTAGE ----