## WIRING DIAGRAM

## **Q5SN Series Convertible Packaged/Electric Heat Pump** 208-230/460 Volt Three Phase 60 Hz. NOTES: 4. For supply wire ampacities and overcurrent protection, see unit 1. Disconnect all power before servicing. 1. Couper le courant avant de faire letretien. 2. For supply connections use copper conductors only. rating label. 2. Employez uniquement des conducteurs en cuivre. 3. If any of the original wire as supplied with the furnace must be replaced, 5. On 120C Models only. For 208V operation remove wire from 230V it must be replaced with wiring material having a temperature rating of tap and place on 208V tap. at least 105C. Outdoor Fan Motor Defrost Board Relay Operation: LVT-R (1) Closes during defrost. Rating: 1 A Maximum Aux. Switch →>нк-1 T2 💽 (2) Opens during defrost. Rating: 1/2 HP at 230 VAC Maximum (N.O.)

