WIRING DIAGRAM H3HK008H-01C **240VAC** 8 KW,10 KW, 2-Circuit, 1-Phase Electric Heater Kit H3HK010H-01C BROWN-CONTACTOR LIMIT CONTACTOR **ELEMENT** 3 4 5 6 YELLOW **BROWN** GREY 8 9-PIN **HEATER PLUG** BLACK COMPRESSOR CONTACTOR NOTES: 0 0 1. Circuit breakers are not wired to heater kit by the factory, see Installation Instructions for wiring procedure. **TERMINAL** 2. If any of the original wire supplied with this unit must **BLOCK** be replaced, it must be replaced with wiring material **Ģ**L1 Ø 1 0 of the same gauge size and temperature rating. The installation of this heater kit may require a change in the blower speed tap connection. See Installation Instructions for details. CIRCUIT 3. Use copper conductors with a minimum temperature rating **BREAKERS** of 60 C for supply connections. LEGEND: FIELD WIRING ---711443B LOW VOLTAGE **CIRCUIT B** (Replaces 711443A) HIGH VOLTAGE = CIRCUIT A